



**OFFICE OF THE FIRE OFFICER,
NORTHERN RANGE, SAMBALPUR**

Phone- 0663-2546050, Fax- 0663-2546056, E-mail- fonr-sbp@gov.in

**FORM-V
FIRE SAFETY CERTIFICATE**

(See rule-13 (3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No. G-222-2019

Certificate No. 33/2021/NR (FPW)

Dated. 27.01.2021

This Certificate is valid up to 26.01.2025


(Apply for renewal at least three months before expiry)

Certified that the **G+3 floors Boy's Hostel Building (Block- A, B & C) of Vikash Residential Institution, Plot No. 174 & 175, Khata No.141/78 At- Pabapali, Dist- Sambalpur** consist of total 03 (Three) numbers of block was inspected by officers of the Fire Service on 20.02.2020 & 20.01.2021 in presence of the applicant and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules, 2017 read with Odisha Fire Prevention and Fire Safety (Amendment) Rules-2019 and Govt. Notification No. 28850/CD, HOME-FS-PERM-0003-2020, BBSR, Dtd. 28.08.2020 and that the building is fit for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below.

1.	Ground to 3 rd floor	--Usage--	(Block- A, B & C) (Hostel) Residential
----	---------------------------------	-----------	---

CONDITIONS:-

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier(s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The set-backs, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupiers (s) shall train all staff and occupants periodically to make them well conversant in use and operation of Fire prevention and safety measures.
4. Fire drills/Rehearsals should be organized at least one in six months by involving local Fire Stations.
5. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/ corridors in all floors of all Towers/Blocks of building/ premises.


27.01.21
Fire Officer,
Northern Range Sambalpur